

State of Vermont
Construction Section
National Life Building, Drawer 33
Montpelier, VT 05633
www.aot.state.vt.us

[phone] 802-828-2593
[fax] 802-828-2795
[ttd] 800-253-0191

Agency of Transportation

Brian Emmons
T. Buck Construction, Inc.
249 Merrow Road
Auburn, ME 48009

November 27, 2013

RE: MIDDLEBURY RS 0174(8) CONTRACTOR EROSION PREVENTION AND SEDIMENT CONTROL PLAN

Dear Brian:

VTrans has completed its review of the Contractor Erosion Prevention and Sediment Control (EPSC) Plan. The Plan is considered **accepted** once the below comments are addressed.

Special Provision 652.03 requires certain qualifications for the Plan Preparer. The qualifications of the Plan Preparer were not disclosed in the EPSC Plan submittal. Please amend you plan to include the Plan Preparer qualifications as required in the EPSC Plan Contractor Checklist.

The Environmental Special Provision #16 indicates sensitive archaeology in the surrounding area. Please be familiar with this provision.

The contracted earth disturbance is proposed to be 0.94 acres. Please understand that the threshold requiring a construction stormwater permit form VT DEC is 1 acre of earth disturbance.

Any material stockpiling that will take place in the roadway shall be contained as to prevent turbid runoff from leaving the site.

There is mention of a work platform under the arch. Are more specific details forth coming? Since this is considered State land you must coordinate with us when working with the regulators.

If you have any questions, please contact me at (802) 828-5483.

Sincerely,

William Farley P.E., CPESC

VTrans Assistant Construction Environmental Engineer

cc: Joe Knipes, VTrans Resident Engineer

Mark Mackintosh, VTrans SW Regional Engineer

Jennifer Fitch, VTrans Project Manager

Andrea Wright, VTrans Construction Environmental Engineer

Project File
